

Vales Point Power Station Monthly Data Summary



LICENCE NO	761	http://www.epa.nsw.gov.au/prpoeapp/
LICENCE HOLDER	SUNSET POWER INTERNATIONAL PTY LTD	
REPORTING PERIOD	MARCH 2016	
ADDRESS	VALES POINT ROAD, MANNERING PARK NSW	

POINT 1 Discharge to waters. Cooling water outlet at Wyee Bay approximately 1000m west of the premises. Labelled VPOC on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865												
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	98.5% limit	Exceedance (yes/no)	Comments
March 2016	Chlorine (free residual)	milligrams per litre	Monthly	1		0.05	0.05	0.05	0.2		No	
March 2016	Temperature	degrees celsius	Continuous	100%	March 2016	29.0	32.7	35.6	37.5	35	No	98.5% limit not exceeded for year to date
March 2016	Oil and Grease	Visible	Continuous	100%	March 2016	NIL	NIL	NIL			No	No visible oil or grease detected during March 2016

POINT 2 Discharge to waters. Discharge from the ash water recycle system to the cooling water outlet canal. Labelled VPADB on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865												
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	98.5% limit	Exceedance (yes/no)	Comments
March 2016	Ammonia	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Cadmium	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Copper	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Lead	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Managanese	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	2/03/2016	0.03	0.03	0.03				
March 2016	Nitrogen (total)	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	pH	pH	Monthly	1	2/03/2016	8.08	8.08	8.08	6.5 - 9.5		No	
March 2016	Phosphorus (total)	milligrams per litre	Monthly	1	2/03/2016	0.08	0.08	0.08				
March 2016	Reactive Phosphorus	milligrams per litre	Monthly	1	2/03/2016	0.01	0.01	0.01				
March 2016	Selenium	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Total Kjeldahl Nitrogen	milligrams per litre	Quarterly	0								Not required for March 2016
March 2016	Total Suspended Solids	milligrams per litre	Fortnightly	5	1, 2, 15, 22 & 29/3/16	7	17	36	50		No	
March 2016	Zinc	milligrams per litre	Quarterly	0								Not required for March 2016

POINT 4 Discharge to waters. Seepage from ash dam rehabilitated area. Labelled VPADS on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865												
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	98.5% limit	Exceedance (yes/no)	Comments
March 2016	Ammonia	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Cadmium	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Copper	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Lead	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Managanese	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	2/03/2016	0.36	0.36	0.36				
March 2016	Nitrogen (total)	milligrams per litre	Quarterly									Not required for March 2016
March 2016	pH	pH	Monthly	1	2/03/2016	7.76	7.76	7.76				
March 2016	Phosphorus (total)	milligrams per litre	Monthly	1	2/03/2016	0.03	0.03	0.03				
March 2016	Selenium	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Total Kjeldahl Nitrogen	milligrams per litre	Quarterly									Not required for March 2016
March 2016	Total Suspended Solids	milligrams per litre	Monthly	1	2/03/2016	3	3	3	50		No	
March 2016	Zinc	milligrams per litre	Quarterly									Not required for March 2016

POINT 18 Discharge to waters. Overboarding of Ash Dam at discharge point. Labelled as VPADD on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865												
Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	98.5% limit	Exceedance (yes/no)	Comments
March 2016	Ammonia	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Cadmium	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Copper	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Lead	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Managanese	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Nitrogen (total)	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	pH	pH	Daily for discharge >2 hrs						6.5 - 9.0			No discharge during March 2016
March 2016	Phosphorus (total)	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Selenium	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Total Kjeldahl Nitrogen	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016
March 2016	Total Suspended Solids	milligrams per litre	Daily for discharge >2 hrs						50			No discharge during March 2016
March 2016	Zinc	milligrams per litre	Daily for discharge >2 hrs									No discharge during March 2016

POINT 11 Discharge to air. Stack serving boiler unit 5, labelled point 11 on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/286:

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
March 2016	Cadmium	milligrams per cubic metre	Yearly						1		Sampling complete. Report not yet received.
March 2016	Chlorine	milligrams per cubic metre	Yearly						200		Sampling complete. Report not yet received.
March 2016	Copper	milligrams per cubic metre	Yearly								Sampling complete. Report not yet received.
March 2016	Hydrogen chloride	milligrams per cubic metre	Yearly						100		Sampling complete. Report not yet received.
March 2016	Mercury	milligrams per cubic metre	Yearly						1		Sampling complete. Report not yet received.
March 2016	Moisture	percent	Yearly								Sampling complete. Report not yet received.
March 2016	Molecular weight of stack gases	grams per gram mole	Yearly								Sampling complete. Report not yet received.
March 2016	Nitrogen Oxides	milligrams per cubic metre	Continuous	100%	March 2016	421	577	679	1500	No	
March 2016	Sulfuric acid mist and sulfur trioxide (as SO3)	milligrams per cubic metre	Yearly						100		Sampling complete. Report not yet received.
March 2016	Sulphur dioxide	parts per million	Continuous	100%	March 2016	178	203	236	600	No	
March 2016	Temperature	degrees Celsius	Yearly								Sampling complete. Report not yet received.
March 2016	Total Fluoride	milligrams per cubic metre	Yearly						50		Sampling complete. Report not yet received.
March 2016	Total Solid Particles	milligrams per cubic metre	Yearly						100		Sampling complete. Report not yet received.
March 2016	Type 1 and Type 2 substances in aggregate	milligrams per cubic metre	Yearly						5		Sampling complete. Report not yet received.
March 2016	Undifferentiated Particulates	milligrams per cubic metre	Continuous	93.5%	March 2016	10.6	18.1	34.8			
March 2016	Velocity	metres per second	Yearly								Sampling complete. Report not yet received.
March 2016	Volatile organic compounds	parts per million	Yearly								Sampling complete. Report not yet received.
March 2016	Volumetric flowrate	cubic metres per second	Yearly								Sampling complete. Report not yet received.

POINT 12 Discharge to air. Stack serving boiler unit 6, labelled point 12 on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/286:

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
March 2016	Cadmium	milligrams per cubic metre	Yearly						1		Sampling complete. Report not yet received.
March 2016	Chlorine	milligrams per cubic metre	Yearly						200		Sampling complete. Report not yet received.
March 2016	Copper	milligrams per cubic metre	Yearly								Sampling complete. Report not yet received.
March 2016	Hydrogen chloride	milligrams per cubic metre	Yearly						100		Sampling complete. Report not yet received.
March 2016	Mercury	milligrams per cubic metre	Yearly						1		Sampling complete. Report not yet received.
March 2016	Moisture	percent	Yearly								Sampling complete. Report not yet received.
March 2016	Molecular weight of stack gases	grams per gram mole	Yearly								Sampling complete. Report not yet received.
March 2016	Nitrogen Oxides	milligrams per cubic metre	Continuous	100%	March 2016	531	919	1059	1500	No	
March 2016	Sulfuric acid mist and sulfur trioxide (as SO3)	milligrams per cubic metre	Yearly						100		Sampling complete. Report not yet received.
March 2016	Sulphur dioxide	parts per million	Continuous	100%	March 2016	146	190	241	600	No	
March 2016	Temperature	degrees Celsius	Yearly								Sampling complete. Report not yet received.
March 2016	Total Fluoride	milligrams per cubic metre	Yearly						50		Sampling complete. Report not yet received.
March 2016	Total Solid Particles	milligrams per cubic metre	Yearly						100		Sampling complete. Report not yet received.
March 2016	Type 1 and Type 2 substances in aggregate	milligrams per cubic metre	Yearly						5		Sampling complete. Report not yet received.
March 2016	Undifferentiated Particulates	milligrams per cubic metre	Continuous	100%	March 2016	3.9	17.3	28.8			
March 2016	Velocity	metres per second	Yearly								Sampling complete. Report not yet received.
March 2016	Volatile organic compounds	parts per million	Yearly								Sampling complete. Report not yet received.
March 2016	Volumetric flowrate	cubic metres per second	Yearly								Sampling complete. Report not yet received.

GENERAL COMMENTS

2015-16 Stack Testing on Points 11 & 12 completed by contractor late March 2016. Final Stack Test report with results is due in early May.