

Vales Point Power Station Monthly Environmental Data Summary



LICENCE NO	761	http://www.epa.nsw.gov.au/prpoeoapp/
LICENCE HOLDER	SUNSET POWER INTERNATIONAL PTY LTD	
REPORTING PERIOD	JUNE 2016	
ADDRESS	VALES POINT ROAD, MANNERING PARK NSW	

POINT 1 Discharge to waters. Cooling water outlet at Wyee Bay approximately 1000m west of the premises. Labelled VPOC on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	98.5% limit	Exceedance (yes/no)	Comments
June 2016	Chlorine (free residual)	milligrams per litre	Monthly	1	1/06/2016	0.05	0.05	0.05	0.2		No	
June 2016	Temperature	degrees celsius	Continuous	100%	June 2016	18.6	25.2	29.9	37.5	35	No	98.5% limit not exceeded for 2015/16 reporting period.
June 2016	Oil and Grease	Visible	Continuous	100%	June 2016	NIL	NIL	NIL			No	No visible oil or grease detected during June 2016

POINT 2 Discharge to waters. Discharge from the ash water recycle system to the cooling water outlet canal. Labelled VPADB on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
June 2016	Ammonia	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Cadmium	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Copper	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Lead	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Manganese	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	1/06/2016	0.04	0.04	0.04			
June 2016	Nitrogen (total)	milligrams per litre	Quarterly								Not required for June 2016
June 2016	pH	pH	Monthly	1	1/06/2016	8.61	8.61	8.61	6.5 - 9.5	No	
June 2016	Phosphorus (total)	milligrams per litre	Monthly	1	1/06/2016	0.14	0.14	0.14			
June 2016	Reactive Phosphorus	milligrams per litre	Monthly	1	1/06/2016	0.06	0.06	0.06			
June 2016	Selenium	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Total Kjeldahl Nitrogen	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Total Suspended Solids	milligrams per litre	Fortnightly	4	1, 6, 15 & 20/06/2016	10	22	49	50	No	
June 2016	Zinc	milligrams per litre	Quarterly								Not required for June 2016

POINT 4 Discharge to waters. Seepage from ash dam rehabilitated area. Labelled VPADS on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
June 2016	Ammonia	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Cadmium	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Copper	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Lead	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Manganese	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	1/06/2016	0.37	0.37	0.37			All seepage water pumped back to ash dam during June 2016
June 2016	Nitrogen (total)	milligrams per litre	Quarterly								Not required for June 2016
June 2016	pH	pH	Monthly	1	1/06/2016	7.86	7.86	7.86			All seepage water pumped back to ash dam during June 2016
June 2016	Phosphorus (total)	milligrams per litre	Monthly	1	1/06/2016	<0.02	<0.02	<0.02			All seepage water pumped back to ash dam during June 2016
June 2016	Selenium	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Total Kjeldahl Nitrogen	milligrams per litre	Quarterly								Not required for June 2016
June 2016	Total Suspended Solids	milligrams per litre	Monthly	1	1/06/2016	8	8	8	50	No	All seepage water pumped back to ash dam during June 2016
June 2016	Zinc	milligrams per litre	Quarterly								Not required for June 2016

POINT 18 Discharge to waters. Overboarding of Ash Dam at discharge point. Labelled as VPADD on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
June 2016	Ammonia	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Cadmium	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Copper	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Lead	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Manganese	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Nitrogen (total)	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	pH	pH	Daily for discharge >2 hrs						6.5 - 9.0		No discharge during June 2016
June 2016	Phosphorus (total)	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Selenium	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Total Kjeldahl Nitrogen	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016
June 2016	Total Suspended Solids	milligrams per litre	Daily for discharge >2 hrs						50		No discharge during June 2016
June 2016	Zinc	milligrams per litre	Daily for discharge >2 hrs								No discharge during June 2016

POINT 11 Discharge to air. Stack serving boiler unit 5, labelled point 11 on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
June 2016	Cadmium	milligrams per cubic metre	Yearly						1	No	
June 2016	Chlorine	milligrams per cubic metre	Yearly						200	No	
June 2016	Copper	milligrams per cubic metre	Yearly								
June 2016	Hydrogen chloride	milligrams per cubic metre	Yearly						100	No	
June 2016	Mercury	milligrams per cubic metre	Yearly						1	No	
June 2016	Moisture	percent	Yearly								
June 2016	Molecular weight of stack gases	grams per gram mole	Yearly								
June 2016	Nitrogen Oxides	milligrams per cubic metre	Continuous	100%	June 2016	473	573	692	1500	No	
June 2016	Sulfuric acid mist and sulfur trioxide (as SO3)	milligrams per cubic metre	Yearly						100	No	
June 2016	Sulphur dioxide	parts per million	Continuous	100%	June 2016	186	222	236	600	No	
June 2016	Temperature	degrees Celsius	Yearly								
June 2016	Total Fluoride	milligrams per cubic metre	Yearly						50	No	
June 2016	Total Solid Particles	milligrams per cubic metre	Yearly						100	No	
June 2016	Type 1 and Type 2 substances in aggregate	milligrams per cubic metre	Yearly						5	No	
June 2016	Undifferentiated Particulates	milligrams per cubic metre	Continuous	100%	June 2016	9.7	16.5	48.9			
June 2016	Velocity	metres per second	Yearly								
June 2016	Volatile organic compounds	parts per million	Yearly								
June 2016	Volumetric flowrate	cubic metres per second	Yearly								

POINT 12 Discharge to air. Stack serving boiler unit 6, labelled point 12 on plan of premises VX837351 15/11/13 DOC14/1645 EF 13/2865

Month	Pollutant	Unit of Measure	Sample/Measurement Frequency	Samples Collected & Analysed	Date Sampled	Lowest Sample Value	Mean of Samples	Highest Sample Value	EPL Limit	Exceedance (yes/no)	Comments
June 2016	Cadmium	milligrams per cubic metre	Yearly						1	No	
June 2016	Chlorine	milligrams per cubic metre	Yearly						200	No	
June 2016	Copper	milligrams per cubic metre	Yearly								
June 2016	Hydrogen chloride	milligrams per cubic metre	Yearly						100	No	
June 2016	Mercury	milligrams per cubic metre	Yearly						1	No	
June 2016	Moisture	percent	Yearly								
June 2016	Molecular weight of stack gases	grams per gram mole	Yearly								
June 2016	Nitrogen Oxides	milligrams per cubic metre	Continuous	100%	June 2016	634	857	1021	1500	No	
June 2016	Sulfuric acid mist and sulfur trioxide (as SO3)	milligrams per cubic metre	Yearly						100	No	
June 2016	Sulphur dioxide	parts per million	Continuous	100%	June 2016	145	215	249	600	No	
June 2016	Temperature	degrees Celsius	Yearly								
June 2016	Total Fluoride	milligrams per cubic metre	Yearly						50	No	
June 2016	Total Solid Particles	milligrams per cubic metre	Yearly						100	No	
June 2016	Type 1 and Type 2 substances in aggregate	milligrams per cubic metre	Yearly						5	No	
June 2016	Undifferentiated Particulates	milligrams per cubic metre	Continuous	100%	June 2016	5.3	9.2	15.3			
June 2016	Velocity	metres per second	Yearly								
June 2016	Volatile organic compounds	parts per million	Yearly								
June 2016	Volumetric flowrate	cubic metres per second	Yearly								

GENERAL COMMENTS

- Unit 6 Outage was completed on 6 June 2016 and the unit was returned to service and synchronised with the grid on 8 June 2016
- Last annual stack test on Points 11 & 12 completed in March 2016 and reported in April 2016. Next annual stack test scheduled for February/March 2017.