

Copyright © 2017 Delta Electricity ABN 75 162 696 335

Community Information | [Site map](#) | [Staff Login](#) | [Accessibility](#) | [Privacy](#) | [Copyright](#) | [Contact Us](#)

General Enquiries & Complaints (24 hours) Phone (02) 4352 6111

The planned outage at Vales Point Power Station is near completion and the unit will be returned to service within the next 48 hours.

[Contact Us](#)

[Admin Login](#)

---

# Quotation

DELTA ELECTRICITY

SPECIFICATION AND QUOTATION NO.C1231/20

VALES POINT POWER STATION

ABRASIVE BLASTING AND LOCTITE APPLICATION

## SUMMARY OF SPECIFICATION

The following summary indicates the general nature of the Works for which The Principal desires Tenders to be submitted and is issued to enable Contractors to make an assessment whether the Specification documents should be obtained from The Principal for the purpose of submitting a tender response. It does not form part of the Specification and should not be included as part of the Tenderer's offer.

## PURPOSE OF WORK

The Contractor is responsible for dry film thickness testing, mechanical surface preparation, supply and application of Loctite wearing compounds to worn pulveriser mechanical components as required, for a (2) two year period at Vales Point Power Station.

## LOCATION OF SITE

The Vales Point Power Station is located on the southern shore of Lake Macquarie, approximately 130 km north of Sydney, New South Wales, and approximately 3 km off the Pacific Highway North of Doyalson.

## EXTENT OF WORK

The Contractor will be required to carry out but not be limited to the following works:

- a) Mechanical removal of previously applied wear compounds from components as required;

